



BRUHAT BENGALURU MAHANAGARA PALIKE

Medical Officer of Health, Byatarayanapura, Yelahanka Zone, Bangalore-92

NO. BBMP/YZ/MOH(BTP)/PR/25-26

Date: 07.05.2025.



SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certifies that an inspection team headed by Senior Health Inspector Ward No.05-BBMP inspected the **ORCHIDS THE INTERNATIONAL SCHOOL, No.1/4, Sampigehalli, Jakkur post, Bengaluru-560064** on 07.05.2025 and found that **ORCHIDS THE INTERNATIONAL** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the State Government.

The above is valid for a period of - 1 year


Medical Officer of Health
Byatarayanapura Division
Yelahanka Zone
BBMP, Bangalore-92

To,

**ORCHIDS THE INTERNATIONAL SCHOOL,
No.1/4, Sampigehalli,
Jakkur post, Bengaluru-560064**


PRINCIPAL
JAKKUR BRANCH

Sampigehalli, Chokkanahalli Main Road,
Bengaluru, Karnataka 560064

For VIVEKAVARDHINI EDUCATION SOCIETY(R)



PRESIDENT

BRUHAT BENGALURU MAHANAGARA PALIKE

Medical Officer of Health, Byatarayanapura, Yelahanka Zone, Bangalore – 92.

NO.BBMP / YZ / MOH (BTP) / PR / 29 (A) / 2025-26

DATE: 07-05-2025

Seal of
Medical Officer of Health,
Byatarayanapura, Yelahanka Zone,
Bangalore – 92

**SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

It is certified that an inspection team headed by Senior Health Inspector Ward No.05—BBMP inspected the **ORCHIDS THE INTERNATIONAL SCHOOL, No.1/4, Sampigehalli, Jakkur Post, Bengaluru – 560064** on 07.05.2025 and found that **ORCHIDS THE INTERNATIONAL SCHOOL** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building and the campus as per norms prescribed by the State Government.

The above is valid for a period of - 1 year

Seal of
Medical Officer of Health,
Byatarayanapura, Yelahanka Zone,
Bangalore – 92

Signature with Seal:

Sd/-

Medical Officer of Health
Byatarayanapura Division
Yelahanka Zone,
BBMP, Bangalore – 92

ORCHIDS THE INTERNATIONAL SCHOOL
No.1/4, Sampigehalli,
Jakkur Post, Bengaluru – 560064.


PRINCIPAL
JAKKUR BRANCH

Sampigehalli, Chokkanahalli Main Road,
Bengaluru, Karnataka 560064

TRANSLATED BY ME


G. DAYANANDA
Advocate & Notary
Govt. of India
61, 2nd Floor, 7th Cross
M-Hebbalwaram Bangalore - 560 008



For VIVEKAWARDHINI EDUCATION SOCIETY(R)


PRESIDENT

GOVERNMENT OF KARNATAKA

No: PH/Water/BAC/ 44/25-26
bvinicbat

Office of the Joint Director
Public Health Institute
Bengaluru - 560 001

Dated: 19-04-2025

Report of Bacteriological analysis of Water/Effluent sample

Sample No.	Source & Particulars of Water Sample	Opinion				S.P.P	N.S.P.P	N.S.P.P & FC.
		M.P.N Count	Plate Count	D.C Test				
141	RO water B.No. 7129471	Nil	-	-		SPP	-	-

Note:

M.P.N Count:

Most probable number of Bacteria per 100ml of Water

D.C Test:

Differential Colliform test

Plate Count:

Plate Count per ml of sample

SPP:

Water is satisfactory for Potable purpose

NSPP:

Water is not satisfactory for Drinking purpose

NSPP & FC:

Water is not satisfactory for Drinking purpose and E.Coli found

S. V. S. S. S.
PRINCIPAL
JAKKUR BRANCH

Sampigehalli, Chokkanahalli Main Road,
Bengaluru, Karnataka 560064

For VIVEKAVARDHINI EDUCATION SOCIETY(R)

[Signature]
PRESIDENT

[Signature]
For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE
Bengaluru

(PTO)

Principal
Jakkur Branch
Sampige Halli, Chokkanahalli Main Road,
Bengaluru, Karnataka 560064

Sample.....
Need effective chlorination before use

2. Sample.....

Need to avoid possible source of faecal contamination and effective chlorination before use
For the purpose of chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

	CLASS 1	CLASS 2	CLASS 3	CLASS 4
E.coli count per 100 ml	0	0	0	0.1 or More
Presumptive Coliform count per 100ml	0	1-3	4-10	Greater than 10
	Excellent	Satisfactory	Suspicious	Unsatisfactory

For VIVEKAVARDHINI EDUCATION SOCIETY(R)

PRESIDENT

PRINCIPAL
JAKKUR BRANCH

Sampige Halli, Chokkanahalli Main Road,
Bengaluru, Karnataka 560064